



Product Service

CERTIFICATE

No. Z2 127197 0001 Rev. 00

Holder of Certificate: **Voltec Solar SAS**
1 Rue des Prés
67190 Dinsheim sur Bruche
FRANCE

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062473701-00

Valid until: 2029-09-04

Date, 2024-09-05

(Zhulin Zhang)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICATE



CERTIFICATE

No. Z2 127197 0001 Rev. 00

Model(s): Tarka 120 VSBP XXX, XXX= 475 to 500 in steps of 5
 Tarka 110 VSBP XXX, XXX= 435 to 460 in steps of 5
 Tarka 120 VSMP XXX, XXX= 475 to 500 in steps of 5
 Tarka 110 VSMP XXX, XXX= 435 to 460 in steps of 5
 XXX is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

Tested according to: IEC 61215-1:2021
 IEC 61215-1-1:2021
 IEC 61215-2:2021
 IEC 61730-1:2023
 IEC 61730-2:2023